


Government of Bihar
Public Health Engineering Department
District Level Water Testing Laboratory - Public Health Division - Kaimur (Bhabua)



पब्लिक हेल्थ इंजीनियरिंग

District - **Kaimur (Bhabua)** Issue Date - **30-10-24**


Drinking Water Quality Test Monitoring Report


Water Sample Details


Sl. No.	Block	Panchayat / Town	Village / Locality	Habitation / Ward No.	Source of sample	Sample received date	Sample Tested date	Tested Parameter in mg/L (Except pH)										Remarks
								pH	Turb.	EC	TDS	T. Hard	T. Alka	Ca	Mg	Cl	F	
1	Kudra	Kudra	Kudra	Paradise Children Academy, Lalpur Kudra	Filter Water	25-10-24	30-10-24	6.51	< 0.5	61.00	39.00	32.00	36.00	4.81	4.86	16	0.15	
2	Kudra	Kudra	Kudra	Paradise Children Academy, Lalpur Kudra	Submersible	25-10-24	30-10-24	7.00	< 1.0	724.00	474.00	252.00	256.00	48.10	32.08	36	2.98	
Desirable Limit								6.5-8.5	1.0	--	500	200	200	75	30	250	1	
Permissible limit in absence of alternate source (IS 10500-2012) 2nd revision								NR	5.0	--	2000	600	600	200	100	1000	1.5	


* The above list of Water Sample collected and submitted in laboratory for water quality test by - Paradise Children Academy - Staff. (Mob - 9431845922)

Note :- All the parameter tested in this laboratory are found within the maximum permissible limit Except fluoride in Sample no 2.


P. Kumar
 Chemist 10/24
 DLWT- Lab, P.H. Division,
 Kaimur (Bhabua)


Executive Engineer
 Public Health Division
 Kaimur (Bhabua)


PRINCIPAL
Paradise Children Academy
 Lalapur (Kudra) Kaimur
 Aff.No - 330308. SC 45285


Samir Kumar
 Manager
Paradise Children Academy
 Lalapur Kudra

28

20

009